




# CA2Z

## CLASS A INITIATING DEVICE MODULE



**Transient Protected**  
**Built In 5.1k End Of Line Resistor**  
**PC Board Assembly:** Mounts to JFS-C1 Releasing Control Panel stand-offs




P/N 18631

### Description

The Model CA2Z Class A Module is designed to be used with the Janus Fire Systems® JFS-C1 Releasing Control Panel to convert from two (Class B) initiating device circuits to two (Class A) circuits.


The module is to be mounted in the upper right hand corner of the panel. Connection to the panel is made via the 8 pin header mounted on the back side of the CA2Z.

### Mounting





## Typical Wiring



*Note: Approvals/Listings maintained by and manufactured by Potter Electric Signal Company.*

The seller makes no warranties, express or implied, including, but not limited to, the implied warranties of merchantability and fitness for a particular purpose, except as expressly stated in the seller's sales contract or sales acknowledgment form. Every attempt is made to keep our product information up-to-date and accurate. All specific applications cannot be covered, nor can all requirements be anticipated. All specifications are subject to change without notice.



1102 Rucpich Drive  
Millennium Park  
Crown Point, IN 46307  
TEL: (219) 663-1600 FAX: (219) 663-4562  
e-mail: [info@janusfiresystems.com](mailto:info@janusfiresystems.com)  
[www.janusfiresystems.com](http://www.janusfiresystems.com)