

# LOS-5

## WEATHERPROOF KEYED LOCK-OUT STATION w/ LEDs



P/N: 97415

### Features

- NEMA 4X Enclosure
- Surface Mount
- Key Removable only in Normal (I) Position
- Yellow LED
- Two N.C. Contacts, Two N.O. Contacts
- Enclosure: UL Listed, CE, CSA
- Keyed Selector: UL Listed, CE, CSA
- Pilot Light: UL Listed, CE, CSA


### Description

The Janus Fire Systems® LOS-5 Weatherproof Keyed Lock-Out Station provides a keyed method to disconnect and electrically lock-out the releasing circuit of a fire suppression system. The LOS-5 comes with a key that is removable only in the normal (I) position. The LOS-5 has an aluminum enclosure that is rated NEMA 4X for outdoor use. It ships with an operation instruction plate to be mounted above the station.


### Operation

To lock-out, insert key and turn to locked-out position. The System Disabled LED will light up when the switch is in the locked-out position.

### Dimensions



### Schematic





## Specifications

Temperature:	-13° to 120°F (-25° to 48.9°C)
Weight:	1.5 lbs (0.68 kg)
Dimensions:	5.39 in H x 3.16 in W x 4 in D (137 mm x 80 mm x 101.6 mm)
Color:	Face Plate – Painted Aluminum System Disabled LED – Yellow
Contacts (DPDT) Rating:	4 amps at 30 VAC; 0.5 amps at 30 VDC
Terminal Connections:	2 x 16 AWG, 1 x 14 AWG

## Ordering Information

Model	P/N	Description	Ship Wt. lb (kg)
LOS-5	97415	Keyed Lock-Out Station w LEDs - Weatherproof	1.5 (0.7)
N/A	99997	N.C. Contact Block - Red	0.1 (0.05)
N/A	99998	N.O. Contact Block - Green	0.1 (0.05)
N/A	99996	Replacement Key	0.1 (0.05)

*Note: Listings and Approval are maintained by Teknik Electric Pvt Ltd*

The seller makes no warranties, express or implied, including, but not limited to, the implied warranties of merchantability and fitness for a particular purpose, except as expressly stated in the seller's sales contract or sales acknowledgment form. Every attempt is made to keep our product information up-to-date and accurate. All specific applications cannot be covered, nor can all requirements be anticipated. All specifications are subject to change without notice.



1102 Rupcich Drive  
 Millennium Park  
 Crown Point, IN 46307  
 TEL: (219) 663-1600 FAX: (219) 663-4562  
 e-mail: [info@janusfiresystems.com](mailto:info@janusfiresystems.com)  
[www.janusfiresystems.com](http://www.janusfiresystems.com)